

# DECLARATION

## No. 02/11/2015

Caused by the tests carried out by the Building Research Institute (CPD 1488) test lab for building hardware, it is confirmed herewith that:

The building hardware:

ASSA ABLOY Lever Handle and Knob, series: AHW500, AHW600, AHW700, AHW800 in all configurations

From the distributor:

ASSA ABLOY SP. Z O.O.  
94 Jana Olbrachta Str.  
01-102 Warsaw  
Poland

With the important requirements of:

EN 1906: 2012  
„Lever handles and knob furniture; requirements and test methods”  
EN 1634-1:2014  
“Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware. Fire resistance test for door and shutter assemblies and openable windows

conform and that they can be classified as:

Lever handles with 8 mm square spindle.

1	2	3	4	5	6	7	8
Category of use	Durability	Door mass and closing force	Suitability for use on fire/smoke doors	Safety	Corrosion resistance	Security and drill resistance	Field of door application
<b>3</b>	<b>7</b>	<b>n/a</b>	<b>B</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>B</b>

This declaration is based upon the test reports no. LOW01-1881/13/R06OWN of ITB Poznań and FIRES-FR-096-15-AUNE of FIRES S.R.O.(NB1396)

Warsaw, November 17<sup>th</sup> 2015

By order

Waldemar Maciszewski  
PM & BDM Assa Abloy EE